



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

**MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION**

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786)315-2590 F (786) 31525-99

www.miamidade.gov/economy

Commercial Innovations, Inc.
9105 Way Ave.
Cleveland, OH 44105

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Solar Brite Single Ply Roof Systems over Concrete Decks.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews NOA #12-1102.04 and consists of pages 1 through 49.
The submitted documentation was reviewed by Alex Tigera.



NOA No.: 15-1007.11
Expiration Date: 01/05/21
Approval Date: 12/31/15
Page 1 of 49

ROOFING SYSTEM APPROVAL

Category: Roofing
Sub-Category: Single Ply
Material: KEE
Deck Type: Concrete
Maximum Design Pressure -572.5 psf

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

| <u>Product</u> | <u>Dimensions</u> | <u>Test Specification</u> | <u>Product Description</u> |
|--|---|----------------------------------|---|
| Solar Brite EV, Solar Brite | Various | ASTM D 6754 | Polyester reinforced KEE membrane. |
| Solar Brite EVFB, Solar Brite FB | Various | ASTM D 6754 | KEE, fleece-backed, polyester reinforced, single ply membrane |
| LA432 Bonding Adhesive | | Proprietary | Two side "contact" bonding adhesive |
| LA432M Bonding Adhesive | | Proprietary | Solvent based bonding adhesive |
| FA561M Water Borne Adhesive | | Proprietary | One side "substrate only" fleece back solvent based adhesive |
| FA636 Water Borne Adhesive | | Proprietary | One side "substrate only" fleece backed water based adhesive |
| Millennium One Step™ Foamable Adhesive | | Proprietary | Elastomeric, One step foamable adhesive |
| Tuff Trac | 0.080" x 28" or 56" x 43" ¼" x 24" x 48" | N/A | Vinyl walk way Vinyl protection pad |



APPROVED INSULATIONS:

| TABLE 2 | | |
|-------------------------------------|---|--|
| <u>Product Name</u> | <u>Product Description</u> | <u>Manufacturer (With Current NOA)</u> |
| ACFoam-II, ACFoam-III, ACFoam-IV | Isocyanurate Insulation | Atlas Roofing Corporation |
| DensDeck, DensDeck Prime | Silicon treated gypsum | Georgia-Pacific Gypsum LLC |
| H-Shield, H-Shield CG | Polyisocyanurate Insulation | Hunter Panels, LLC |
| ENRGY 3, ENRGY 3 25 PSI | Isocyanurate Insulation | Johns Manville Corporation |
| XPS | Type IV Extruded polystyrene with a minimum density of 1.6 pcf | Generic |
| EPS | Type IX Expanded polystyrene with a minimum density of 1.8 pcf | Generic |
| Ultra-Max, Multi-Max FA-3 | Polyisocyanurate foam insulation | Rmax Operating, LLC |
| SECUROCK Gypsum-Fiber Roof Board | Gypsum Coverboard | United States Gypsum Corporation |



APPROVED FASTENERS:**TABLE 3**

| <u>Fastener Number</u> | <u>Product Name</u> | <u>Product Description</u> | <u>Dimensions</u> | <u>Manufacturer (With Current NOA)</u> |
|-----------------------------------|--|--|--------------------------|---|
| 1. | Dekfast 1.5" x 2.5" Oval Barbed Plate | Galvalume AZ50 stress plate | 1.5" x 2.5" | SFS Intec, Inc. |
| 2. | Dekfast Galvalume Steel Round 2-3/8 in 20-Ga. Barbed Plate | Barbed, galvalume AZ50 stress plate | 2-3/8" Dia. | SFS Intec, Inc. |
| 3. | Dekfast Isofast IF-2.375-AT Membrane Plate | Galvalume AZ50 stress plate, #15 belted fasteners | 2-3/8" Dia. | SFS Intec, Inc. |
| 4. | Dekfast 12 & 14 Fasteners | Insulation and membrane fasteners | Various | SFS Intec, Inc. |
| 5. | Dekfast 15 HS | Carbon steel fastener for concrete, steel and wood decks | Various | SFS Intec, Inc. |
| 6. | Dekfast Galvalume Steel Hex | Galvalume AZ50 steel plate | 2 7/8" x 3 1/4" | SFS Intec, Inc. |
| 7. | Trufast 3" Metal Insulation Plate | Galvalume AZ50 steel plate | 3" round | Altenloh, Brinck & Co. U.S., Inc. |
| 8. | #14 Roofgrip | Membrane and Insulation fasteners | Various | OMG, Inc. |
| 9. | CD-10 | Membrane and Insulation Fastener | Various | OMG, Inc. |
| 10. | Trufast #21 SHD Fasteners | Insulation fastener for wood, steel and concrete decks | Various | Altenloh, Brinck & Co. U.S., Inc. |
| 11. | Trufast #15 EHD fasteners | Insulation fastener for wood, steel and concrete decks | Various | Altenloh, Brinck & Co. U.S., Inc. |
| 12. | Trufast 2-3/4" Barbed Metal Seam Plate (EHD) | AZ-55 Galvalume steel stress plate | 2.75" round | Altenloh, Brinck & Co. U.S., Inc. |
| 13. | Dekfast 1.5" x 2.75" Oval Barbed Plate | Oval stress plate | 1 1/2" x 2 3/4" | SFS Intec, Inc. |

EVIDENCE SUBMITTED:

| <u>Test Agency/Identifier</u> | <u>Name</u> | <u>Report</u> | <u>Date</u> |
|--|----------------------|------------------|-------------|
| Factory Mutual Research Corp. | FM 4470 | 1Z2A5.AM | 01/12/96 |
| | FM 4470 | 1Z3A8.AM | 08/13.97 |
| | FM 4470 | 3003251 | 10/05/99 |
| | FM 4470 | 4D5A4.AM | 10/05/99 |
| | FM 4470 | 3002471 | 10/06/99 |
| | FM4450 | 3009610 | 10/22/01 |
| | FM 4470 | 3019313 | |
| | FM 4470 | 3028651 | 04/17/08 |
| | FM 4470 | 3036192 | 11/23/09 |
| | FM 4470 | 3033396 | 09/04/09 |
| | FM 4470 | 3037770 | 10/22/09 |
| | FM 4470 | 3013125 | 09/23/03 |
| | FM 4470 | 3013068 | 09/23/03 |
| | FM 4470 | 3032172 | 06/12/09 |
| | FM 4470 | 3012321 | 07/29/02 |
| | FM 4470 | 3044075 | 04/06/12 |
| | FM 4470 | 3045983 | 10/18/12 |
| Underwriters Laboratories | FM 4470 | 3019313 | |
| | UL790 | 95NK17212 | 08/21/98 |
| | UL790 | 94NK12810 | 08/11/98 |
| | UL 790 | 12CA39420 | 01/08/13 |
| Exterior Research & Design, LLC | TAS 114 | 4015.10.96-1-R1 | 07/20/10 |
| | TAS 114 | 4006.07.97-1-R1 | 07/15/10 |
| | TAS 114 | 4020.08.99-1-R1 | 07/15/10 |
| | TAS 114 | 4006.08.00-1-R1 | 10/18/05 |
| | TAS 114 | 02843.02.05-08 | 02/04/05 |
| | TAS 114 | 02843.03.05-1 | 03/25/05 |
| | TAS 114 | 02767.09.05-S1 | 09/27/05 |
| | TAS 117 & ASTM D6862 | C8500SC.11.07-R1 | 08/07/09 |
| | FM 4470 / TAS 114 | S32410.09.10 | 09/21/10 |
| | FM 4470 / TAS 114 | S13040.02.09-R1 | 03/06/09 |
| PRI Construction Materials Technologies LLC | ASTM D 6754 | S47410.12.14 | 12/15/14 |
| | ASTM D 3747 | HGC-142-02-03 | 02/09/12 |

APPROVED ASSEMBLIES

| | |
|--------------------------|---|
| Membrane Type: | Single Ply, KEE |
| Deck Type 3I: | Concrete Decks, Insulated |
| Deck Description: | Min. 2500 psi structural concrete or concrete plank |
| System Type A(1): | One or more layers of insulation adhered with approved <u>adhesive</u> , membrane adhered |

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

Primer: Elastocol Stick applied at 0.4 gal/sq (0.17 l/m²).

Vapor Barrier: Soprapap'r, self-adhered.

| <u>Base Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|---|--|---|
| ENRGY-3 Minimum 1.5" thick | N/A | N/A |
| <u>Top Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
| SECUROCK Gypsum-Fiber Roof Board Minimum 0.25" thick | N/A | N/A |

Note: Apply insulation layer in a ¾" to 1" wide beads 12" o.c. of Millennium One Step Foamable Insulation Adhesive. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: Solar Brite EVFB or Solar Brite FB roof cover fully adhered with spatter-applied 3M Polyurethane Foam Insulation Adhesive CR-20. Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressure: -45 psf (See General Limitation #9.)



Membrane Type: Single Ply, KEE
Deck Type 3I: Concrete Decks, Insulated
Deck Description: Min. 2500 psi structural concrete or concrete plank
System Type A(2): One or more layers of insulation adhered with approved adhesive, membrane adhered

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Barrier: Cold-applied base and/or ply sheet approved for use with the roof cover followed by an
(Optional) additional approved cold-applied sheet. Applied over ASTM D41 primed deck.

One or more layers of the following insulations:

| <u>Base Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|---|---|--|
| Approved EPS or XPS Minimum 1.5" thick | N/A | N/A |
| <u>Top Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
| DensDeck, DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board Minimum 0.25" thick | N/A | N/A |

Note: All insulation shall be adhered to the deck or vapor barrier in 3" to 3.5" wide beads 12" o.c. of TITE-SET Roofing Adhesive or 3M Polyurethane Foam Insulation Adhesive CR-20. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: Solar Brite EV or Solar Brite roof cover adhered to the insulation with LA 432 Bonding Adhesive or LA 432M Bonding Adhesive applied at an application rate of 50 ft²/gal. Laps are sealed with 1.5-inch heat weld.

Or

Solar Brite EVFB or Solar Brite FB roof cover adhered to the insulation with approved asphalt at 20-25 lbs./sq., FA 561M solvent adhesive at 90 ft²/gal or FA 636 water based adhesive at 100 ft²/gal. Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressure: -67.5 psf (See General Limitation #9)



Membrane Type: Single Ply, KEE
Deck Type 3I: Concrete Decks, Insulated
Deck Description: Min. 2500 psi structural concrete or concrete plank
System Type A(3): One or more layers of insulation adhered with approved adhesive, membrane adhered

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Barrier: (Optional) Cold-applied base and/or ply sheet approved for use with the roof cover followed by an additional approved cold-applied sheet.

One or more layers of the following insulations:

| <u>Base Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|--|--|---|
| ACFoam-II, Multi-Max FA-3, H-Shield, ENRGY 3 Minimum: 1.5" thick | N/A | N/A |
| <u>Top Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
| ACFoam-II, Multi-Max FA-3, H-Shield, ENRGY 3 Minimum: 1.5 " thick | N/A | N/A |
| ACFoam-II, Multi-Max FA-3, H-Shield, ENRGY 3 Tapered | N/A | N/A |

Note: All insulation shall be adhered to the deck or vapor barrier in TITE-SET Roofing Adhesive or 3M Polyurethane Foam Insulation Adhesive CR-20 applied in continuous 3-inch ribbons spaced 12" o.c. Refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: Solar Brite EV or Solar Brite roof cover adhered with LA 432 Bonding Adhesive or LA 432M Bonding Adhesive adhesive applied at a rate of 1 gal/sq. to the back side of the membrane and to the substrate. Laps are sealed with 1.5-inch heat weld.
 Or
 Solar Brite EVFB or Solar Brite FB roof cover adhered with hot asphalt at 25 lbs/sq., FA 561M adhesive at 1 gal/sq. or with FA 636 water based adhesive at 100 ft²/gal. Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressure: -67.5 psf (See General Limitation #9)



Membrane Type: Single Ply, KEE
Deck Type 3I: Concrete Decks, Insulated
Deck Description: Min. 2500 psi structural concrete or concrete plank
System Type A(4): One or more layers of insulation adhered with approved adhesive, membrane adhered

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Barrier: (Optional) Cold-applied base and/or ply sheet approved for use with the roof cover followed by an additional cold-applied sheet.

One or more layers of the following insulations:

| <u>Base Insulation Layer (Optional)</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|---|--|---|
| ACFoam-II, Multi-Max FA-3, H-Shield, ENRGY 3 Minimum: 1.5" thick | N/A | N/A |
| <u>Top Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
| DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board Minimum: 0.25 " thick | N/A | N/A |

Note: All insulation shall be adhered to the deck or vapor barrier in TITE-SET Roofing Adhesive or 3M Polyurethane Foam Insulation Adhesive CR-20 applied in continuous 3-inch ribbons spaced 12" o.c. Refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: Solar Brite EV or Solar Brite roof cover adhered with LA 432 Bonding Adhesive or LA 432M Bonding Adhesive applied at a rate of 1 gal/sq. to the back side of the membrane and to the substrate. Laps are sealed with 1.5-inch heat weld.

Or

Solar Brite EVFB or Solar Brite FB roof cover adhered with hot asphalt at 25 lbs/sq., or FA 561M solvent adhesive at 1 gal. per 100 ft² or FA 636 water based adhesive at 100 ft²/gal. Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressure: -67.5 psf (See General Limitation #9)



Membrane Type: Single Ply, KEE
Deck Type 3I: Concrete Decks, Insulated
Deck Description: Min. 2500 psi structural concrete or concrete plank
System Type A(5): One or more layers of insulation adhered with approved adhesive, membrane adhered

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Barrier: Hot-applied, Self-Adhering or Torch-applied vapor barrier as indicated below:
(Optional)
 Hot asphalt-applied base and/or ply sheets approved for use with roof cover followed by an additional approved asphalt-applied sheet.
 Or
 Self-adhered base membrane approved for use with roof cover followed by an additional approved self-adhered sheet.
 Or
 Hot asphalt-applied base and/or ply sheets or optional torch-applied base membrane approved for use with roof cover followed by an additional approved torch-applied sheet.

One or more layers of the following insulations:

| <u>Base Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|--|---|--|
| ACFoam-II, Multi-Max FA-3, H-Shield, ENRGY 3 Minimum: 1.5" thick | N/A | N/A |
| <u>Top Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
| ACFoam-II, Multi-Max FA-3, H-Shield, ENRGY 3 Minimum: 1.5 " thick | N/A | N/A |

Note: All insulation shall be adhered to the deck or vapor barrier in TITE-SET Roofing Adhesive or 3M Polyurethane Foam Insulation Adhesive CR-20 applied in continuous 3-inch ribbons spaced 12" o.c. Refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: Solar Brite EVFB or Solar Brite FB roof cover adhered with FA 561M adhesive at 1 gal/sq or FA 636 water based adhesive at 100 ft²/gal.
Maximum Design Pressure: -105 psf (See General Limitation #9)
 Or
 Solar Brite EV or Solar Brite roof cover adhered with LA 432 Bonding Adhesive or LA 432M Bonding Adhesive applied at a rate of 1 gal/sq. to the back side of the membrane and to the substrate.
Maximum Design Pressure: -169 psf with torch-applied vapor barrier (See General Limitation #9)
Maximum Design Pressure: -210 psf with hot-applied, self-adhered or no vapor barrier

(See General Limitation #9)

**Maximum Design
Pressure:**

See Membrane Options above



Membrane Type: Single Ply, KEE
Deck Type 3I: Concrete Decks, Insulated
Deck Description: Min. 2500 psi structural concrete or concrete plank
System Type A(6): One or more layers of insulation adhered with approved adhesive, membrane adhered

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Barrier: Hot-applied, Self-Adhering or Torch-applied vapor barrier as indicated below:
(Optional)
 Hot asphalt-applied base and/or ply sheets approved for use with roof cover followed by an additional approved asphalt-applied sheet.
 Or
 Self-adhered base membrane approved for use with roof cover followed by an additional approved self-adhered sheet.
 Or
 Hot asphalt-applied base and/or ply sheets or optional torch-applied base membrane approved for use with roof cover followed by an additional approved torch-applied sheet.

One or more layers of the following insulations:

| <u>Base Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|---|---|--|
| ACFoam-II, Multi-Max FA-3, H-Shield, ENRGY 3 Minimum: 1.5" thick | N/A | N/A |
| <u>Top Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
| ACFoam-II, Multi-Max FA-3, H-Shield, ENRGY 3 Tapered | N/A | N/A |

Note: All insulation shall be adhered to the deck or vapor barrier in TITE-SET Roofing Adhesive or 3M Polyurethane Foam Insulation Adhesive CR-20 applied in continuous 3-inch ribbons spaced 12" o.c. Refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: Solar Brite EVFB or Solar Brite FB roof cover adhered with FA 561M adhesive at 1 gal/sq or FA 636 water based adhesive at 100 ft²/gal.
Maximum Design Pressure: -105 psf (See General Limitation #9)
 Or
 Solar Brite EV or Solar Brite roof cover adhered with LA 432 Bonding Adhesive or LA 432M Bonding Adhesive applied at a rate of 1 gal/sq. to the back side of the membrane and to the substrate.
Maximum Design Pressure: -117 psf (See General Limitation #9)

Maximum Design Pressure: See Membrane Options above



Membrane Type: Single Ply, KEE
Deck Type 3I: Concrete Decks, Insulated
Deck Description: Min. 2500 psi structural concrete or concrete plank
System Type A(7): One or more layers of insulation adhered with approved adhesive, membrane adhered

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

| <u>Base Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|---|--|---|
| ACFoam-II, Multi-Max FA-3, ENRGY 3, Approved EPS or XPS Minimum 1.5" thick | N/A | N/A |
| <u>Top Insulation Layer (Optional, required over EPS)</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
| ACFoam-II, Multi-Max FA-3, ENRGY 3 Minimum 1.5" thick | N/A | N/A |
| DensDeck Prime or SECUROCK Gypsum-Fiber Roof Board Minimum 0.25" thick | N/A | N/A |

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of insulation. All insulation shall be adhered to the deck in ¾" to 1" wide beads 12" o.c. of Millennium One Step Foamable Adhesive or Insta-Stik Quik Set Insulation Adhesive or OlyBond Adhesive Fastener at application rate of 1gal/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: Solar Brite EV or Solar Brite roof cover adhered to the insulation with LA 432 Bonding Adhesive or LA 432M Bonding Adhesive applied at an application rate of 1 gal./sq. to the backside of the membrane and to the substrate. Laps are sealed with 1.5-inch heat weld.

Or

Solar Brite EVFB or Solar Brite FB roof cover adhered to the insulation with approved asphalt at 20-25 lbs./sq., FA 561M solvent adhesive at 1 gal. per 100 ft² or FA 636 water based adhesive at 100 ft²/gal. Laps are sealed with 1.5-inch heat weld.



**Maximum Design
Pressure:**

-82.5 psf (for Millennium One Step Foamable Adhesive, Insta-Stik Quik Set Insulation Adhesive or OlyBond Fastener Adhesive) (See General Limitation #9)

-90 psf (for for Insta-Stik Quik Set Insulation Adhesive & Solar Brite EVFB or Solar Brite FB Application) (See General Limitation #9)

-120 psf (for for Insta-Stik Quik Set Insulation Adhesive & Solar Brite EV or Solar Brite Application) (See General Limitation #9)



Membrane Type: Single Ply, KEE
Deck Type 3I: Concrete Decks, Insulated
Deck Description: Min. 2500 psi structural concrete or concrete plank
System Type A(8): One or more layers of insulation adhered with approved adhesive, membrane adhered

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Barrier: Any UL or FM approved vapor barrier may be installed over the deck.
(Optional)

One or more layers of the following insulations:

| <u>Base Insulation Layer (Optional)</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|---|--|---|
| ACFoam-II, ACFoam-III, Multi-Max FA-3, H-Shield Minimum 1.5" thick | N/A | N/A |
| DensDeck, DensDeck Prime Minimum 0.5" thick | N/A | N/A |
| <u>Top Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
| ACFoam-II, ACFoam-III, Multi-Max FA-3, H-Shield Tapered | N/A | N/A |

Note: All insulation shall be adhered to the deck in 3-3.5" wide beads spaced 12" o.c. of TITE-SET Roofing Adhesive or 3M Polyurethane Foam Insulation Adhesive CR-20. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: Solar Brite EV or Solar Brite roof cover adhered to the insulation with LA 432 Bonding Adhesive or LA 432M Bonding Adhesive applied at an application rate of 1 gal./sq. to the backside of the membrane and to the substrate. Laps are sealed with 1.5-inch heat weld.
 Or
 Solar Brite EVFB or Solar Brite FB roof cover adhered to the insulation with approved asphalt at 20-25 lbs./sq., or FA 561M solvent adhesive at 1 gal. per 100 ft² or FA 636 water based adhesive at 100 ft²/gal. Laps are sealed with 1.5-inch heat weld..

Maximum Design Pressure: -90.0 psf (See General Limitation #9)



Membrane Type: Single Ply, KEE
Deck Type 3I: Concrete Decks, Insulated
Deck Description: Min. 2500 psi structural concrete or concrete plank
System Type A(9): One or more layers of insulation adhered with approved adhesive, membrane adhered

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

Primer: Elastocol Stick applied at 0.4 gal/sq (0.17 l/m²).

Vapor Barrier: Soprapap'r, self-adhered.

| <u>Base Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|---|---|--|
| ENRGY-3 Minimum 1.5" thick | N/A | N/A |
| <u>Top Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
| SECUROCK Gypsum-Fiber Roof Board Minimum 0.25" thick | N/A | N/A |

Note: Apply insulation layer in a ¾" to 1" wide beads 12" o.c. of Millennium One Step Foamable Insulation Adhesive. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: Solar Brite EVFB or Solar Brite FB roof cover fully adhered with approved asphalt at 20-25 lbs./sq., FA 561M solvent adhesive at 90 ft²/gal or FA 636 water based adhesive at 100 ft²/gal. Laps are sealed with 1.5-inch heat weld.

Or

Solar Brite EV roof cover adhered with LA 432 Bonding Adhesive or LA 432M Bonding Adhesive applied at an application rate 0.5 gal/sq. Laps are sealed with 1.5-inch heat weld.

Or

Solar Brite roof cover adhered with FA 636 water based adhesive at 0.66 gal/sq. Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressure: -157.5 psf; with membrane adhesives (See General Limitation #9.)
-180 psf; with hot asphalt (See General Limitation #9.)



Membrane Type: Single Ply, KEE
Deck Type 3I: Concrete Decks, Insulated
Deck Description: Min. 2500 psi structural concrete or concrete plank
System Type A(10): One or more layers of insulation adhered with approved adhesive, membrane adhered

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Barrier: Any UL or FM approved vapor barrier may be installed over the deck.
(Optional)

One or more layers of the following insulations:

| <u>Base Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|---|--|---|
| ACFoam-II, Ultra-Max, ENRGY 3, H-Shield Minimum 1.5" thick | N/A | N/A |
| <u>Top Insulation Layer (Optional)</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
| DensDeck, DensDeck Prime or SECUROCK Gypsum-Fiber Roof Board Minimum 0.25" thick | N/A | N/A |

Note: All insulation shall be adhered to the deck in ½" to ¾" wide beads 12" o.c. of Millennium One Step Foamable Adhesive. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: Solar Brite EV or Solar Brite roof cover adhered to the insulation with LA 432 Bonding Adhesive or LA 432M Bonding Adhesive applied at an application rate of 1 gal./sq. to the backside of the membrane and to the substrate. Laps are sealed with 1.5-inch heat weld.
 Or
 Solar Brite EVFB or Solar Brite FB roof cover adhered to the insulation with approved asphalt at 20-25 lbs./sq., or FA 561M solvent adhesive at 1 gal. per 100 ft² or FA 636 water based adhesive at 100 ft²/gal. Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressure: -157.5 psf (with vapor barrier) (See General Limitation #9)
 -232.5 psf (with no vapor barrier) (See General Limitation #9)



Membrane Type: Single Ply, KEE
Deck Type 3I: Concrete Decks, Insulated
Deck Description: Min. 2500 psi structural concrete or concrete plank
System Type A(11): One or more layers of insulation adhered with approved adhesive, membrane adhered

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Barrier: (Optional) Hot asphalt-applied base and/or ply sheets or optional torch-applied base membrane approved for use with roof cover followed by an additional approved torch-applied sheet.

One or more layers of the following insulations:

| <u>Base Insulation Layer (Optional)</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|--|--|---|
| ACFoam-II, Multi-Max FA-3, H-Shield, ENRGY 3 or Approved EPS or XPS Minimum: 1.5" thick | N/A | N/A |
| <u>Top Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
| DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board Minimum: 0.25 " thick | N/A | N/A |

Note: All insulation shall be adhered to the deck or vapor barrier in TITE-SET Roofing Adhesive or 3M Polyurethane Foam Insulation Adhesive CR-20 applied in continuous 3-inch ribbons spaced 12" o.c. Refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: Solar Brite EV or Solar Brite roof cover adhered with LA 432 Bonding Adhesive or LA 432M Bonding Adhesive applied at a rate of 1 gal/sq. to the back side of the membrane and to the substrate. Laps are sealed with 1.5-inch heat weld.
 Or
 Solar Brite EVFB or Solar Brite FB roof cover adhered with hot asphalt at 25 lbs/sq. or FA 561M solvent adhesive at 1 gal. per 100 ft² or FA 636 water based adhesive at 100 ft²/gal. Laps are sealed with 1.5-inch heat weld

Maximum Design Pressure: -169 psf (See General Limitation #9)



Membrane Type: Single Ply, KEE
Deck Type 3I: Concrete Decks, Insulated
Deck Description: Min. 2500 psi structural concrete or concrete plank
System Type A(12): One or more layers of insulation adhered with approved adhesive, membrane adhered

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Barrier: Hot-applied or Self-Adhering vapor barrier as indicated below:
(Optional)
 Hot asphalt-applied base and/or ply sheets approved for use with roof cover followed by an additional approved asphalt-applied sheet.
 Or
 Self-adhered base membrane approved for use with roof cover followed by an additional approved self-adhered sheet.

One or more layers of the following insulations:

| <u>Base Insulation Layer (Optional)</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|---|--|---|
| Approved EPS or XPS Minimum: 1.5" thick | N/A | N/A |
| <u>Top Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
| DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board Minimum: 0.25 " thick | N/A | N/A |

Note: All insulation shall be adhered to the deck or vapor barrier in TITE-SET Roofing Adhesive or 3M Polyurethane Foam Insulation Adhesive CR-20 applied in continuous 3-inch ribbons spaced 12" o.c. Refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: Solar Brite EV or Solar Brite roof cover adhered with LA 432 Bonding Adhesive or LA 432M Bonding Adhesive applied at a rate of 1 gal/sq. to the back side of the membrane and to the substrate. Laps are sealed with 1.5-inch heat weld.
 Or
 Solar Brite EVFB or Solar Brite FB roof cover adhered with hot asphalt at 25 lbs/sq., or FA 561M solvent adhesive at 1 gal. per 100 ft² or FA 636 water based adhesive at 100 ft²/gal. Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressure: -180 psf (See General Limitation #9)



Membrane Type: Single Ply, KEE

Deck Type 3I: Concrete Decks, Insulated

Deck Description: Min. 2500 psi structural concrete or concrete plank

System Type A(13): One or more layers of insulation adhered with approved adhesive, membrane adhered

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

| <u>Base Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|---|---|--|
| Approved EPS or XPS Minimum 1.0" thick (Maximum 4'x4') | N/A | N/A |
| <u>Top Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
| DensDeck, DensDeck Prime or SECUROCK Gypsum-Fiber Roof Board Minimum 0.25" thick | N/A | N/A |

Note: All insulation shall be adhered to the deck in ½" to ¾" wide beads 12" o.c. of Millennium One Step Foamable Adhesive. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: Solar Brite EV or Solar Brite roof cover adhered to the insulation with LA 432 Bonding Adhesive or LA 432M Bonding Adhesive applied at an application rate of 1 gal./sq. to the backside of the membrane and to the substrate. Laps are sealed with 1.5-inch heat weld.

Or

Solar Brite EVFB or Solar Brite FB roof cover adhered to the insulation with approved asphalt at 20-25 lbs./sq., or FA 561M solvent adhesive at 1 gal. per 100 ft² or FA 636 water based adhesive at 100 ft²/gal. Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressure: -202.5 psf (See General Limitation #9)



Membrane Type: Single Ply, KEE
Deck Type 3I: Concrete Decks, Insulated
Deck Description: Min. 2500 psi structural concrete or concrete plank
System Type A(14): All layers of insulation adhered subsequently membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Barrier: Any approved asphaltic vapor barrier.
(Optional)

One or more layers of the following:

| <u>Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|--|---|--|
| H-Shield, ENRGY 3, ACFoam-II, Multi-Max FA-3 Minimum 1.0" thick | N/A | N/A |

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of insulation. All insulation shall be adhered to the deck in full mopping of approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: Solar Brite EV or Solar Brite roof cover adhered to the insulation with LA 432 Bonding Adhesive or LA 432M Bonding Adhesive applied at an application rate of 1 gal./sq. Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressures: -210.0 psf (See General Limitation #9.)



Membrane Type: Single Ply, KEE
Deck Type 3I: Concrete Decks, Insulated
Deck Description: Min, 2500 psi structural concrete or concrete plank
System Type A(15): One or more layers of insulation adhered with approved asphalt, membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Barrier: Any UL or FM approved asphaltic vapor barrier may be installed over the substrate.
(Optional)

One or more layers of the following insulations:

| <u>Base Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|--|--|---|
| ACFoam-II, Multi-Max FA-3, H-Shield, ENRGY 3 Minimum 1.5" thick | N/A | N/A |
| <u>Top Insulation Layer (Optional)</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
| ACFoam-II, Multi-Max FA-3, H-Shield, ENRGY 3 Minimum 1.5" thick | N/A | N/A |
| DensDeck Prime Minimum 0.25" thick | N/A | N/A |

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of insulation. All insulation shall be adhered to the deck in full mopping of approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels used as a top layer shall be placed with the polyisocyanurate side facing down.

Membrane: Solar Brite EV or Solar Brite roof cover adhered to the insulation with LA 432 Bonding Adhesive or LA 432M Bonding Adhesive applied at an application rate of 1 gal./sq. to the backside of the membrane and to the substrate. Laps are sealed with 1.5-inch heat weld.

Or

Solar Brite EVFB or Solar Brite FB roof cover adhered to the insulation with approved asphalt at 20-25 lbs./sq., or FA 561M solvent adhesive at 1 gal. per 100 ft² or FA 636 water based adhesive at 100 ft²/gal. Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressure: -240 psf; (See General Limitation #9.)



Membrane Type: Single Ply, KEE
Deck Type 3I: Concrete Decks, Insulated
Deck Description: Min. 2500 psi structural concrete or concrete plank
System Type A(16): One or more layers of insulation adhered with approved adhesive, membrane adhered

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Barrier: Any UL or FM approved asphaltic vapor barrier may be installed over the substrate.
(Optional)

One or more layers of the following insulations:

| <u>Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|--|---|--|
| ACFoam-II, ACFoam-III, Multi-Max FA-3, H-Shield Minimum 1.5" thick | N/A | N/A |
| DensDeck, DensDeck Prime Minimum 0.5" thick | N/A | N/A |

Note: All insulation shall be adhered to the deck in 3-3.5" wide beads spaced 12" o.c. of TITE-SET Roofing Adhesive or 3M Polyurethane Foam Insulation Adhesive CR-20. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: Solar Brite EV or Solar Brite roof cover adhered to the insulation with LA 432 Bonding Adhesive or LA 432M Bonding Adhesive applied at an application rate of 1 gal./sq. to the backside of the membrane and to the substrate. Laps are sealed with 1.5-inch heat weld.
 Or
 Solar Brite EVFB or Solar Brite FB roof cover adhered to the insulation with approved asphalt at 20-25 lbs./sq., or FA 561M solvent adhesive at 1 gal. per 100 ft² or FA 636 water based adhesive at 100 ft²/gal. Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressure: -240.0 psf (See General Limitation #9)



Membrane Type: Single Ply, KEE
Deck Type 3I: Concrete Decks, Insulated
Deck Description: Min. 2500 psi structural concrete or concrete plank
System Type A(17): One or more layers of insulation adhered with approved adhesive, membrane adhered

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

| <u>Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|---|---|--|
| ACFoam-II, ACFoam-III Minimum 1.5" thick | N/A | N/A |

Note: All insulation shall be adhered to the deck in 3-3.5" wide beads spaced 12" o.c. of TITE-SET Roofing Adhesive or 3M Polyurethane Foam Insulation Adhesive CR-20. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: Solar Brite EV or Solar Brite roof cover adhered to the insulation with LA 432 Bonding Adhesive or LA 432M Bonding Adhesive applied at an application rate of 1 gal./sq. to the backside of the membrane and to the substrate. Laps are sealed with 1.5-inch heat weld.
 Or
 Solar Brite EVFB or Solar Brite FB roof cover adhered to the insulation with approved asphalt at 20-25 lbs./sq., or FA 561M solvent adhesive at 1 gal. per 100 ft² or FA 636 water based adhesive at 100 ft²/gal. Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressure: -240.0 psf (See General Limitation #9)



Membrane Type: Single Ply, KEE
Deck Type 3I: Concrete Decks, Insulated
Deck Description: Min. 2500 psi structural concrete or concrete plank
System Type A(18): One or more layers of insulation adhered with approved adhesive, membrane adhered

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Barrier: Hot-applied or Self-Adhering vapor barrier as indicated below:
(Optional) Hot asphalt-applied base and/or ply sheets approved for use with roof cover followed by an additional approved asphalt-applied sheet.
 Or
 Self-adhered base membrane approved for use with roof cover followed by an additional approved self-adhered sheet.

One or more layers of the following insulations:

| <u>Base Insulation Layer (Optional)</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|---|--|---|
| ACFoam-II, Multi-Max FA-3, H-Shield, ENRGY 3 or Approved EPS or XPS(min. 2.0 pcf) Minimum: 1.5" thick | N/A | N/A |
| <u>Top Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
| DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board Minimum: ¼ " thick | N/A | N/A |

Note: All insulation shall be adhered to the deck or vapor barrier in TITE-SET Roofing Adhesive or 3M Polyurethane Foam Insulation Adhesive CR-20 applied in continuous 3-inch ribbons spaced 12" o.c. Refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: Solar Brite EV or Solar Brite roof cover adhered with LA 432 Bonding Adhesive or LA 432M Bonding Adhesive applied at a rate of 1 gal/sq. to the back side of the membrane and to the substrate. Laps are sealed with 1.5-inch heat weld.
 Or
 Solar Brite EVFB or Solar Brite FB roof cover adhered with hot asphalt at 25 lbs/sq., or FA 561M solvent adhesive at 1 gal. per 100 ft² or FA 636 water based adhesive at 100 ft²/gal. Laps are sealed with 1.5-inch heat weld

Maximum Design Pressure: -240 psf (See General Limitation #9)



Membrane Type: Single Ply, KEE
Deck Type 3I: Concrete Decks, Insulated
Deck Description: Min. 2500 psi structural concrete or concrete plank
System Type A(19): One or more layers of insulation adhered with approved adhesive, membrane adhered

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of any of the following insulations.

| <u>Base Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|--|--|---|
| ACFoam-IV Minimum 2.0" thick | N/A | N/A |
| Multi-Max FA-3 Minimum 1.5" thick | N/A | N/A |
| ACFoam-III Minimum 1.3" thick | N/A | N/A |
| H-Shield CG, ENRGY 3 Minimum 1.0" thick | N/A | N/A |
| <u>Top Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
| SECUROCK Gypsum-Fiber Roof Board, DensDeck, DensDeck Prime Minimum 1/4" thick | N/A | N/A |

Note: All insulation shall be adhered to the deck with TITE-SET Roofing Adhesive or 3M Polyurethane Foam Insulation Adhesive CR-20 applied in 1.5" ribbons spaced 12" o.c. Adhesive shall be allowed to sit for approx. 1 minute before insulation is applied. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: Solar Brite EV or Solar Brite roof cover adhered to the insulation with LA 432M Bonding Adhesive applied at an application rate of 50 ft²/gal.
 Or
 Solar Brite EVFB or Solar Brite FB roof cover adhered to the top insulation layer with approved asphalt at 20-25 lbs./sq., FA 561M solvent adhesive at 90 ft²/gal., or FA 636 water based adhesive at 100 ft²/gal.

Maximum Design Pressure: -240.0 psf (See General Limitation # 9)



Membrane Type: Single Ply, KEE
Deck Type 3I: Concrete Decks, Insulated
Deck Description: Min. 2500 psi structural concrete or concrete plank
System Type A(20): One or more layers of insulation adhered with approved adhesive, membrane adhered

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

| <u>Base Insulation Layer (Optional)</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|---|--|---|
| ACFoam II Minimum 2" thick | N/A | N/A |
| <u>Top Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
| SECUROCK Gypsum-Fiber Roof Board Minimum 0.25" thick | N/A | N/A |

Note: All insulation shall be adhered to the deck in ¾" to 1" wide beads 12" o.c. of Insta-Stik Quik Set Insulation Adhesive or OlyBond 500, TITE-SET Roofing Adhesive, 3M Polyurethane Foam Insulation Adhesive CR-20, or Millennium One Step™ Foamable Insulation Adhesive or full mopping of approved asphalt At a rate of 25 lbs/sq. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: Solar Brite EV or Solar Brite roof cover adhered to the insulation with LA 432 Bonding Adhesive or LA 432M Bonding Adhesive applied at an application rate of 50 ft²/gal. Laps are sealed with 1.5-inch heat weld.
 Or
 Solar Brite EVFB or Solar Brite FB roof cover adhered to the insulation with approved asphalt at 20-25 lbs./sq., FA 561M solvent adhesive at 90 ft²/gal or FA 636 water based adhesive at 100 ft²/gal. Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressures: -247.5 psf (See General Limitation #9.)



Membrane Type: Single Ply, KEE
Deck Type 3I: Concrete Decks, Insulated
Deck Description: Min. 2500 psi structural concrete or concrete plank
System Type A(21): One or more layers of insulation adhered with approved adhesive, membrane adhered

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

| <u>Base Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|--|--|---|
| ACFoam-II, ACFoam-III, Multi-Max FA-3 Minimum 1.5" thick | N/A | N/A |
| <u>Top Insulation Layer (Optional)</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
| DensDeck, DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board Minimum 0.5" thick | N/A | N/A |

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of insulation. All insulation shall be adhered to the deck in 3" to 3.5" wide beads 12" o.c. of TITE-SET Roofing Adhesive or 3M Polyurethane Foam Insulation Adhesive CR-20. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: Solar Brite EV or Solar Brite roof cover adhered to the insulation with LA 432 Bonding Adhesive or LA 432M Bonding Adhesive applied at an application rate of 50 ft²/gal.
 Or
 Solar Brite EVFB or Solar Brite FB roof cover adhered to the insulation with approved asphalt at 20-25 lbs./sq., FA 561M solvent adhesive at 90 ft²/gal, or FA 636 water based adhesive at 100 ft²/gal

Maximum Design Pressures: -262.5 psf (See General Limitation #9)



Membrane Type: Single Ply, Thermoplastic
Deck Type 3I: Concrete Decks, Insulated
Deck Description: Min. 2500 psi structural concrete or concrete plank
System Type A(22): All layers of insulation adhered subsequently membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

| <u>Base Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|---|---|--|
| ENRGY 3, ACFoam-II, H-Shield Minimum 1.5" thick | N/A | N/A |
| <u>Top Insulation Layer (Optional)</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
| DensDeck, DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board Minimum 0.25" thick | N/A | N/A |

Note: All insulation shall be adhered to the deck in full mopping of approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: Solar Brite EV or Solar Brite roof cover adhered to the insulation with LA 432M Bonding Adhesive applied at an application rate of 50 ft²/gal.
 Or
 Solar Brite EVFB or Solar Brite FB roof cover adhered to the top insulation layer with approved asphalt at 20-25 lbs./sq., FA 561M solvent adhesive at 90 ft²/gal., or FA 636 water based adhesive at 100 ft²/gal.
Note: Asphalt application shall only be used when adhering to gypsum-based insulation.

Maximum Design Pressure: -290 psf; (See General Limitation #9.)



Membrane Type: Single Ply, Thermoplastic
Deck Type 3I: Concrete Decks, Insulated
Deck Description: Min. 2500 psi structural concrete or concrete plank
System Type A(23): All layers of insulation adhered subsequently membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

| <u>Base Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|---|--|---|
| ENRGY 3, AC Foam-II, H-Shield Minimum 1.5" thick | N/A | N/A |

Note: All insulation shall be adhered to the deck in full mopping of approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: Solar Brite EV or Solar Brite roof cover adhered to the insulation with LA 432M Bonding Adhesive applied at an application rate of 50 ft²/gal.
 Or
 Solar Brite EVFB or Solar Brite FB roof cover adhered to the top insulation layer with FA 561M solvent adhesive at 90 ft²/gal., or FA 636 water based adhesive at 100 ft²/gal.

Maximum Design Pressure: -410 psf; (See General Limitation #9.)



Membrane Type: Single Ply, KEE
Deck Type 3I: Concrete Decks, Insulated
Deck Description: Min. 2500 psi structural concrete or concrete plank
System Type A(24): All layers of insulation adhered subsequently membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

| <u>Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|---|--|---|
| DensDeck Prime Minimum 0.25" thick | N/A | N/A |

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of insulation. All insulation shall be adhered to the deck in full mopping of approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels used as a top layer shall be placed with the polyisocyanurate side facing down.

Membrane: Solar Brite EV or Solar Brite cover adhered to the DensDeck Prime with LA 432 Bonding Adhesive or LA 432M Bonding Adhesive applied at an application rate of 1 gal./sp. To the backside of the membrane and to the substrate. Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressures: -420 psf (See General Limitation #9.)



Membrane Type: Single Ply, Thermoplastic
Deck Type 3I: Concrete Decks, Insulated
Deck Description: Min. 2500 psi structural concrete or concrete plank
System Type A(25): All layers of insulation adhered subsequently membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

| <u>Base Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|---|--|---|
| ACFoam-II Minimum 1.5" thick | N/A | N/A |

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of insulation. All insulation shall be adhered to the deck in full mopping of approved asphalt within the EVT range and at a rate of 25 lbs/square. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: Solar Brite roof cover adhered to the insulation with LA 432M Bonding Adhesive applied at an application rate of 0.5 gal/square (applied to both substrate and roof cover).

Maximum Design Pressure: -495 psf; (See General Limitation #9.)



Membrane Type: Single Ply, KEE
Deck Type 3I: Concrete Decks, Insulated
Deck Description: Min. 2500 psi structural concrete or concrete plank
System Type B: Base layer of insulation mechanically attached, top layer adhered; membrane adhered

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Barrier: (Optional) Any UL or FM approved vapor barrier may be installed over the deck or the base layer of insulation.

Fire Barrier: (Optional) Min. ¼" DensDeck, DensDeck Prime applied to the base or top insulation layer in a full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs./100 ft² or in ¾" to 1" wide beads 12" o.c. of Millennium One Step™ Foamable Insulation Adhesive or Insta-Stik Quik Set Insulation Adhesive or OlyBond Adhesive Fastener at application rate of 1gal/100 ft².

One or more layers of the following insulations:

| <u>Base Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|--|--|---|
| ACFoam-II, Multi-Max FA-3, H-Shield, ENRGY 3 | | |
| Minimum 1.5" thick | 4(#14) | 1:2 ft ² |
| Minimum 2" thick | 4(#14) | 1:4 ft ² |

Note: Base layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

| <u>Top Insulation Layer (Optional)</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|---|--|---|
| ACFoam-II, Multi-Max FA-3, ENRGY 3, H-Shield | | |
| Minimum 1.5" thick | N/A | N/A |

Note: Apply top layer of insulation in a full mopping of any approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft² or ¾" to 1" wide beads 12" o.c. of Millennium One Step™ Foamable Insulation Adhesive or Insta-Stik Quik Set Insulation Adhesive or OlyBond Adhesive Fastener at application rate of 1gal/100 ft².. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.



Membrane:

Solar Brite EV or Solar Brite roof cover adhered to the insulation with LA 432 Bonding Adhesive or LA 432M Bonding Adhesive applied at an application rate of 1 gal./sq. to the backside of the membrane and to the substrate. Laps are sealed with 1.5-inch heat weld.

Or

Solar Brite EVFB or Solar Brite FB roof cover adhered to the insulation with approved asphalt at 20-25 lbs./sq., FA 561M solvent adhesive at 1 gal. per 100 ft² or FA 636 water based adhesive at 100 ft²/gal. Laps are sealed with 1.5-inch heat weld.

Maximum Design

Pressure:

-45 psf (See General Limitation #9.)



Membrane Type: Single Ply, KEE
Deck Type 3I: Concrete Decks, Insulated
Deck Description: Min. 2500 psi structural concrete or concrete plank
System Type C: All layers of insulation simultaneously attached; membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Barrier: (Optional) Any UL or FM approved vapor barrier may be installed over the deck or the base layer of insulation.

Fire Barrier: (Optional) DensDeck Prime, see Top Insulation Layer for thickness.

One or more layers of the following insulations:

| <u>Base Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|--|--|---|
| ACFoam-II, Multi-Max FA-3, H-Shield, ENRGY 3 Minimum 1" thick | N/A | N/A |
| <u>Top Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
| ACFoam-II, Multi-Max FA-3, H-Shield, ENRGY 3 Minimum 1.5" thick | 4(#14) | 1:2 ft ² |
| Minimum 2" thick | 4(#14) | 1:4 ft ² |
| DensDeck Prime Minimum ½" thick | 4(#14) | 1:1.7 ft ² |
| Minimum ¼" thick | 4(#14) | 1:1.3 ft ² |

Note: All layers shall be simultaneously fastened; see top or base layer for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: Solar Brite EV or Solar Brite roof cover adhered to the insulation with LA 432 Bonding Adhesive or LA 432M Bonding Adhesive applied at an application rate of 1 gal./sq. to the backside of the membrane and to the substrate. Laps are sealed with 1.5-inch heat weld.

Or

Solar Brite EVFB or Solar Brite FB roof cover adhered to the insulation with approved asphalt at 20-25 lbs./sq., FA 561M solvent adhesive at 1 gal. per 100 ft² or FA 636 water based adhesive at 100 ft²/gal. Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressures: -45 psf (See General Limitation #7.)



Membrane Type: Single Ply, Thermoplastic
Deck Type 3I: Concrete Decks, Insulated
Deck Description: Min. 2500 psi structural concrete or concrete plank
System Type D(1): Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

| <u>Base Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|---|--|---|
| ENRGY 3, Multi-Max FA-3, H-Shield, AC Foam-II Minimum 1.5" thick | N/A | N/A |
| <u>Top Insulation Layer (Optional)</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
| DensDeck, DensDeck Prime Minimum 1/4" thick | N/A | N/A |
| Approved High Density Roof Fiberboard Minimum 1/2" thick | N/A | N/A |

Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

Membrane: Solar Brite EV, Solar Brite, Solar Brite EVFB or Solar Brite FB secured through the preliminarily attached insulation as described below.

Fastening #1: Trufast #15 EHD fasteners and Trufast 2-3/4" Barbed Seam Plates (EHD) or Trufast #21 SHD Fasteners and Trufast 2-3/4" Barbed Seam Plates (SHD) spaced 12" o.c. within the 6" wide side laps in rows spaced 94" o.c. The roof cover side laps are sealed with a minimum 1.5" heat weld.
Maximum Design Pressure: -45 psf. (See General Limitation #7)

Fastening #2: Trufast #15 EHD fasteners and Trufast 2-3/4" Barbed Seam Plates (EHD) or Trufast #21 SHD Fasteners and Trufast 2-3/4" Barbed Seam Plates (SHD) spaced 6" o.c. within the 6" wide side laps in rows spaced 94" o.c. The roof cover side laps are sealed with a minimum 1.5" heat weld.
Maximum Design Pressure: -67.5 psf. (See General Limitation #7)

Maximum Design Pressures: See fastening methods above



Membrane Type: Single Ply, KEE
Deck Type 3I: Concrete Decks, Insulated
Deck Description: Min. 2500 psi structural concrete or concrete plank
System Type D(2): Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Barrier: (Optional) Any UL or FM approved vapor barrier applied to the roof deck or over a base layer of insulation.

Fire Barrier: (Optional) Min. ¼" DensDeck or DensDeck Prime attached with 4 fasteners per 4' x 8' sheet.

One or more layers of the following insulations:

| <u>Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|---|---|--|
| ACFoam-II, Ultra-Max, H-Shield, ENRGY 3 Minimum 1.5" thick | N/A | N/A |

Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

Membrane: Solar Brite EV, Solar Brite, Solar Brite EVFB or Solar Brite FB roof cover attached through the preliminary fastened insulation to the deck following one of the fastening methods specified below:

Fastening #1: Fasten with Dekfast 15 HS, OMG CD-10 fasteners and Dekfast 1.5" x 2.5" Oval Barbed Plates or Dekfast 1.5" x 2.75" Oval Barbed Plates spaced 18" o.c. through tabs spaced 51" o.c. Laps are sealed with 1.5-inch heat weld.
Maximum Design Pressure -45 psf. (See General Limitation #7)

Fastening #2: Fasten with Dekfast 15 HS, OMG CD-10 fasteners and Dekfast 1.5" x 2.5" Oval Barbed Plates or Dekfast 1.5" x 2.75" Oval Barbed Plates spaced 12" o.c. through tabs spaced 51" o.c. Laps are sealed with 1.5-inch heat weld.
Maximum Design Pressure -60 psf. (See General Limitation #7)

Fastening #3: Fasten with Dekfast 15 HS, OMG CD-10 fasteners and Dekfast 1.5" x 2.5" Oval Barbed Plates or Dekfast 1.5" x 2.75" Oval Barbed Plates spaced 6" o.c. through the top of the roof cover spaced at maximum intervals of 104.5" Fastener rows are sealed by either welding a 6" cover strip or prefabricated 4.5" surface tab.(closed lap configuration) over the fasteners. The edge of the stripping and/or surface tabs shall be welded a minimum of 1". Laps are sealed with 1.5-inch heat weld.
Maximum Design Pressure -75 psf. (See General Limitation #7)



Fastening #4: Dekfast 15 HS, OMG CD-10 fasteners and Dekfast 1.5" x 2.5" Oval Barbed Plates or Dekfast 1.5" x 2.75" Oval Barbed Plates spaced 6" o.c. within the 5" closed laps in rows spaced 104.5" o.c. The outside 1.5" of the laps is heat welded.
Maximum Design Pressure –82.5 psf. (See General Limitation #7)

Maximum Design Pressures: See Fastening Options Above

Membrane Type: Single Ply, KEE
Deck Type 3I: Concrete Decks, Insulated
Deck Description: Min. 2500 psi structural concrete or concrete plank.
System Type D(3): Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Barrier: (Optional) Any UL or FM approved vapor barrier applied to the roof deck or over a base layer of insulation.

Fire Barrier: (Optional) Min. ¼" DensDeck or DensDeck Prime attached with 4 fasteners per 4' x 8' sheet.

One or more layers of the following insulations:

| <u>Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|---|---|--|
| Any approved polyisocyanurate Listed in Table 2 Minimum 1.5" thick | N/A | N/A |

Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

Membrane: Solar Brite EV or Solar Brite secured through the preliminarily attached insulation as specified below.

Fastening #1: Dekfast fasteners with Dekfast Galvalume Steel Round 2-3/8" 20-Ga. Barbed Plates or Dekfast 15 HS fasteners and Dekfast Isofast IF-2.375-AT Membrane Plates, spaced 6" o.c. within the 5" open laps in rows spaced 144.0" o.c., or installed through integral 3-1/2" fastening tab. The outside 1.5" of the lap is heat welded.
Maximum Design Pressure: -45 psf. (See General Limitation #7)

Fastening #2: Dekfast 15 HS fasteners, OMG CD-10 fasteners with Dekfast 1.5" x 2.5" Oval Barbed Plates or Dekfast 1.5" x 2.75" Oval Barbed Plates spaced 12" o.c. in the 5" lap of membrane in rows spaced 72" o.c. The outside 1.5" of the lap is heat welded.
Maximum Design Pressure: -45 psf. (See General Limitation #7)

Fastening #3: Dekfast fasteners with Dekfast Galvalume Steel Round 2-3/8" 20-Ga. Barbed Plates or Dekfast 15 HS fasteners and Dekfast Isofast IF-2.375-AT Membrane Plate, spaced 6" o.c. through the top of the roof cover in rows spaced 144.0" o.c.. Rows are sealed by either welding a 6" cover strip or prefabricated 4.5" surface tab (closed lap configuration) over the fasteners. The edge of tab or both edges of cover strip are heat welded min. 1.5". Laps are sealed with 1.5-inch heat weld.
Maximum Design Pressure: -52.5 psf. (See General Limitation #7)



- Fastening #4:** Dekfast 15 HS fasteners, OMG CD-10 fasteners with Dekfast 1.5" x 2.5" Oval Barbed Plates or Dekfast 1.5" x 2.75" Oval Barbed Plates spaced 12" o.c. in the 5" lap of membrane in rows spaced 51" o.c. The outside 1.5" of the lap is heat welded.
Maximum Design Pressure: -52.5 psf. (See General Limitation #7)
- Fastening #5:** Dekfast 15 HS fasteners, OMG CD-10 fasteners with Dekfast 1.5" x 2.5" Oval Barbed Plates or Dekfast 1.5" x 2.75" Oval Barbed Plates spaced 6" o.c. in the 5" lap of membrane in rows spaced 96" o.c. The outside 1.5" of the lap is heat welded.
Maximum Design Pressure: -52.5 psf. (See General Limitation #7)
- Fastening #6:** Dekfast 15 HS fasteners, OMG CD-10 fasteners with Dekfast 1.5" x 2.5" Oval Barbed Plates or Dekfast 1.5" x 2.75" Oval Barbed Plates spaced 6" o.c. in the 5" lap of membrane in rows spaced 51" o.c. The outside 1.5" of the lap is heat welded.
Maximum Design Pressure: -67.5 psf. (See General Limitation #7)
- Fastening #7:** Dekfast fasteners with Dekfast Galvalume Steel Round 2-3/8" 20-Ga. Barbed Plates or Dekfast 15 HS fasteners and Dekfast Isofast IF-2.375-AT Membrane Plate, spaced 6" o.c. within the 5" open laps in rows spaced 72.0" o.c. The outside 1.5" of the lap is heat welded, or installed through integral 3-1/2" fastening tab.
Maximum Design Pressure: -67.5 psf. (See General Limitation #7)
- Maximum Design Pressures:** See Fastening Options Above

Membrane Type: Single Ply, KEE
Deck Type 3I: Concrete Decks, Insulated
Deck Description: Min. 2500 psi structural concrete or concrete plank
System Type D(4): Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Barrier: (Optional) Any UL or FM approved vapor barrier applied to the roof deck or over a base layer of insulation.

Fire Barrier: (Optional) Min. 1/4" DensDeck or DensDeck Prime attached with 4 fasteners per 4' x 8' sheet.

One or more layers of the following insulations:

| <u>Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|---|---|--|
| Any approved polyisocyanurate Listed in Table 2 Minimum 1" thick | N/A | N/A |

Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

Membrane: Solar Brite EV or Solar Brite roof cover attached through the presecured insulation to the deck using Dekfast 15 HS fasteners, OMG CD-10 fasteners and Dekfast 1.5" x 2.5" Oval Barbed Plates or Dekfast 1.5" x 2.75" Oval Barbed Plates spaced 6" o.c. through the tabs spaced a maximum of 51" o.c. Laps are sealed with 1.5-inch heat weld.
Maximum Design Pressure: -75 psf (See General Limitation #7)
 Or
 Solar Brite TopSider system consisting of Solar Brite EV or Solar Brite roof cover attached through the presecured insulation to the deck using Dekfast 15 HS, OMG CD-10 fasteners and Dekfast 1.5" x 2.5" Oval Barbed Plates or Dekfast 1.5" x 2.75" Oval Barbed Plates spaced 6" o.c. through the top of the membrane spaced at intervals of 51". Laps are sealed with 1.5-inch heat weld.
Maximum Design Pressure: -90 psf (See General Limitation #7)

Maximum Design Pressures: See Membrane options above.



Membrane Type: Single Ply, KEE
Deck Type 3I: Concrete Decks, Insulated
Deck Description: Min. 2500 psi structural concrete or concrete plank
System Type D(5): Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Barrier: Any UL or FM approved vapor barrier applied to the roof deck or over a base layer of insulation.
(Optional)

Fire Barrier: Min. 1/4" DensDeck or DensDeck Prime attached with 4 fasteners per 4' x 8' sheet.
(Optional)

One or more layers of the following insulations:

| <u>Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|--|---|--|
| ACFoam-II, ACFoam-II, Ultra-Max, Multi-Max FA-3, ENRGY 3, H-Shield Minimum 1" thick | N/A | N/A |
| DensDeck, DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board Minimum 0.25" thick | N/A | N/A |

Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

Membrane: Solar Brite EV or Solar Brite roof cover attached through the preliminary fastened insulation to the deck following one of the fastening methods specified below:

Fastening #1: Fasten with Dekfast 15 HS or OMG #14 Roofgrip fasteners and Dekfast 1.5" x 2.5" Oval Barbed Plates or Dekfast 1.5" x 2.75" Oval Barbed Plates spaced 6" o.c. through 5" wide open laps with a minimum 1.5" field weld or through 3.5" fastening tabs; spaced 51" o.c. Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressure: -112.5 psf. (See General Limitation #7)

Fastening #2: Fasten with Dekfast 15 HS or OMG #14 Roofgrip fasteners and Dekfast 1.5" x 2.5" Oval Barbed Plates or Dekfast 1.5" x 2.75" Oval Barbed Plates spaced 6" o.c. through roof cover in rows spaced 51" o.c. Rows are sealed by either welding a 6" cover strip or prefabricated 4.5" surface tab (closed lap configuration) over the fasteners. The edge of tab or both edges of cover strip are heat welded min. 1.5". Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressure: -112.5 psf. (See General Limitation #7)

Maximum Design Pressures: See Fastening Options Above



Membrane Type: Single Ply, KEE
Deck Type 3: Concrete Decks, Non-Insulated
Deck Description: Min. 2500 psi structural concrete or concrete plank
System Type E(1): Membrane mechanically attached to deck.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Barrier: Any UL or FM approved vapor barrier applied to the roof deck.
(Optional)

Fire Barrier: Min. 1/4" DensDeck or DensDeck Prime attached with 4 fasteners per 4' x 8' sheet.
(Optional)

Membrane: Solar Brite EV or Solar Brite roof cover roof cover attached to the deck following one of the fastening methods specified below:

Fastening #1: Fasten with Dekfast 15 HS fasteners, OMG CD-10 fasteners and Dekfast 1.5" x 2.5" Oval Barbed Plates or Dekfast 1.5" x 2.75" Oval Barbed Plates spaced 18" o.c. through tabs spaced 51" o.c. Laps are sealed with 1.5-inch heat weld.
Maximum Design Pressure: -45 psf. (See General Limitation #7)

Fastening #2: Fasten with Dekfast 15 HS fasteners, OMG CD-10 fasteners and Dekfast 1.5" x 2.5" Oval Barbed Plates or Dekfast 1.5" x 2.75" Oval Barbed Plates spaced 12" o.c. through tabs spaced 51" o.c. Laps are sealed with 1.5-inch heat weld.
Maximum Design Pressure: -60 psf. (See General Limitation #7)

Fastening #3: Fasten with Dekfast 15 HS fasteners, OMG CD-10 fasteners and Dekfast 1.5" x 2.5" Oval Barbed Plates or Dekfast 1.5" x 2.75" Oval Barbed Plates spaced 6" o.c. through the top of the roof cover spaced at maximum intervals of 104.5". Fastener rows are sealed by either welding a 6" cover strip or prefabricated 4.5" surface tab.(closed lap configuration) over the fasteners. The edge of the stripping and/or surface tabs shall be welded a minimum of 1". Laps are sealed with 1.5-inch heat weld.
Maximum Design Pressure: -75 psf. (See General Limitation #7)

Maximum Design Pressure: See Fastening Options above.



Membrane Type: Single Ply, KEE
Deck Type 3: Concrete Decks, Non-Insulated
Deck Description: Min. 2500 psi structural concrete or concrete plank
System Type E(2): Membrane mechanically attached to deck.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Barrier: Any UL or FM approved vapor barrier applied to the roof deck.
(Optional)

Fire Barrier: Min. 1/4" DensDeck or DensDeck Prime attached with 4 fasteners per 4' x 8' sheet.
(Optional)

Membrane: Solar Brite EV or Solar Brite secured through the preliminarily attached insulation as specified below.

Fastening #1: Dekfast 15 HS fasteners, OMG CD-10 fasteners with Dekfast 1.5" x 2.5" Oval Barbed Plates or Dekfast 1.5" x 2.75" Oval Barbed Plates spaced 12" o.c. in the 5" lap of membrane in rows spaced 72" o.c. The outside 1.5" of the lap is heat welded.
Maximum Design Pressure: -45 psf. (See General Limitation #7)

Fastening #2: Dekfast 15 HS fasteners, OMG CD-10 fasteners with Dekfast 1.5" x 2.5" Oval Barbed Plates or Dekfast 1.5" x 2.75" Oval Barbed Plates spaced 6" o.c. in the 5" lap of membrane in rows spaced 96" o.c. The outside 1.5" of the lap is heat welded.
Maximum Design Pressure: -52.5 psf. (See General Limitation #7)

Fastening #3: Dekfast 15 HS fasteners, OMG CD-10 fasteners with Dekfast 1.5" x 2.5" Oval Barbed Plates or Dekfast 1.5" x 2.75" Oval Barbed Plates spaced 12" o.c. in the 5" lap of membrane in rows spaced 51" o.c. The outside 1.5" of the lap is heat welded.
Maximum Design Pressure: -52.5 psf. (See General Limitation #7)

Fastening #4 Dekfast 15 HS fasteners, OMG CD-10 fasteners with Dekfast 1.5" x 2.5" Oval Barbed Plates or Dekfast 1.5" x 2.75" Oval Barbed Plates spaced 6" o.c. in the 5" lap of membrane in rows spaced 51" o.c. The outside 1.5" of the lap is heat welded.
Maximum Design Pressure: -67.5 psf. (See General Limitation #7)

Maximum Design Pressures: See Fastening Options Above



Membrane Type: Single Ply, KEE
Deck Type 3: Concrete Decks, Non-Insulated
Deck Description: Min. 2500 psi structural concrete or concrete plank
System Type E(3): Membrane mechanically attached to deck.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Barrier: Any UL or FM approved vapor barrier applied to the roof deck.
(Optional)
Fire Barrier: Min. 1/4" DensDeck or DensDeck Prime attached with 4 fasteners per 4' x 8' sheet.
(Optional)

Membrane: Solar Brite EV or Solar Brite roof cover attached through the preliminary fastened insulation to the deck following one of the fastening methods specified below:

Fastening #1: Fasten with Dekfast 15 HS fasteners or OMG #14 Roofgrip fasteners and Dekfast 1.5" x 2.5" Oval Barbed Plates or Dekfast 1.5" x 2.75" Oval Barbed Plates spaced 6" o.c. through 5" wide open laps with a minimum 1.5" field weld or through 3.5" fastening tabs; spaced 51" o.c. Laps are sealed with 1.5-inch heat weld.
Maximum Design Pressure: -112.5 psf. (See General Limitation #7)

Fastening #2: Fasten with Dekfast 15 HS fasteners or OMG #14 Roofgrip fasteners and Dekfast 1.5" x 2.5" Oval Barbed Plates or Dekfast 1.5" x 2.75" Oval Barbed Plates spaced 6" o.c. through roof cover in rows spaced 51" o.c. Rows are sealed by either welding a 6" cover strip or prefabricated 4.5" surface tab (closed lap configuration) over the fasteners. The edge of tab or both edges of cover strip are heat welded min. 1.5". Laps are sealed with 1.5-inch heat weld.
Maximum Design Pressure: -112.5 psf. (See General Limitation #7)

Maximum Design Pressures: See Fastening Options Above

Membrane Type: Single Ply, KEE
Deck Type 3: Concrete Decks, Non-Insulated
Deck Description: Min. 2500 psi structural concrete or concrete plank
System Type F(1): Membrane adhered to roof deck.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Membrane: Solar Brite EVFB or Solar Brite FB roof cover adhered to concrete deck sealed with polyvinyl alcohol (PVA) with FA561M Adhesive. Laps are sealed with 1.5-inch heat weld.
Maximum Design Pressure: -372.5 psf (See General Limitation #9)
Or
Solar Brite EVFB or Solar Brite FB roof cover adhered to the primed concrete deck with approved asphalt at 20-25 lbs./sq. or FA 636 water based adhesive at 100 ft²/gal. Laps are sealed with 1.5-inch heat weld.
Maximum Design Pressure: -572.5 psf (See General Limitation #9)

Maximum Design Pressure: See Applications Options above.



Membrane Type: Single Ply, KEE
Deck Type 3: Concrete Decks, Non-Insulated
Deck Description: Min. 2500 psi structural concrete or concrete plank
System Type F(2): Membrane adhered to roof deck.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Membrane: Solar Brite EVFB or Solar Brite FB roof cover adhered to concrete deck with FA 636 water based bonding adhesive applied to substrate at a rate of 0.83 gal/sq. The roof cover side laps are sealed with a minimum 1.5” heat weld

Maximum Design Pressure:
-442.5 psf ; (See General Limitation #9.)
-495.0 psf; For Solar Brite EVFB (See General Limitation #9.)



Membrane Type: Single Ply, KEE
Deck Type 3: Concrete Decks, Non-Insulated
Deck Description: Min. 2500 psi structural concrete or concrete plank
System Type F(3): Membrane adhered to roof deck.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Membrane: Solar Brite EVFB or Solar Brite FB roof cover fully adhered with spatter-applied 3M Polyurethane Foam Insulation Adhesive CR-20. Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressure: -495.0 psf (See General Limitation #9.)



CONCRETE DECK SYSTEM LIMITATIONS:

1. If mechanical attachment to the structural deck through the lightweight insulating concrete is proposed, a field withdrawal resistance testing shall be performed to determine equivalent or enhanced fastener patterns and density. All testing and fastening design shall be in compliance with Testing Application Standard TAS 105 and Roofing Application Standard RAS 117 and/or RAS 137, calculations shall be signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant.

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each sidelap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117 and/or RAS 137. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform with Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE